

Declaration of Conformity

We declare under our sole responsibility that the following products:

Refrigeration Condensing Unit (JEH* Series 3 & 4)

Model Designations:

JEH*-0350-L-3, JEH*-0400-L-3, JEH*-0400-M-3, JEH*-0500-M-3,
JEH*-0600-M-3, JEH*-0675-M-3, JEH*-0725-L-3, JEH*-0825-L-3,
JEH*-0825-M-3, JEH*-1000-M-3

Which are containing refrigerating fluids classified in Group 2 and whose product PS*V in bar×liter is such that $200 < PS*V \leq 1000$ bar.L, are classified in category II according to article 3 of **PRESSURE EQUIPMENT DIRECTIVE 97/23/EC**.

Category: II

Evaluation module: A1

Notified body: Hartford Steam Boiler International GmbH (0871)
Landersumer Weg 40 * D-48431 Rheine, Germany


Technical standards and specification:

are in conformity with the **LOW VOLTAGE DIRECTIVE 2006/95/EC** and
ELECTROMAGNETIC COMPATIBILITY 2004/108/EC.

EMC EN 61000-6-1 (2001) & EN 61000-6-3 (2001)

LVD EN 60335-1 & EN 60335-2-89

The products are provided with a **CE** 0871 marking of conformity.

<p>J & E HALL REFRIGERATION SDN. BHD General Manager  Teh Yeow Chong Issued Date: 3 March 2009</p>

*Note: * denotes as nomenclature for different model or version of condensing unit (eg. JEHCCU & JEH2).*